

# Wind Mitigation Discount

|  |  |
|--|--|
| <b>What Is A Wind Mitigation Discount?</b>                           | <ul style="list-style-type: none"> <li>• This discount is extended to properties that have taken proactive measures to limit damage from high winds.</li> <li>• Some homeowners will fortify their homes above and beyond the required building codes to prevent loss.</li> </ul>  |
| <b>Who Qualifies for This Discount?</b>                              | <ul style="list-style-type: none"> <li>• The system will automatically evaluate all quoted homes for eligibility and apply a discount based on the roof age and year of construction.</li> <li>• Agents should ask, on every quote, if an applicant has had a recent wind mitigation inspection. <ul style="list-style-type: none"> <li>○ If the applicant says no, defaulted values should not be modified.</li> </ul> </li> <li>• <b>NOTE: Agent should never select “No” on the Wind Mitigation Credits question since every property has some defaulted credits.</b></li> </ul>  |
| <b>Which Credits are Determined by a Wind Mitigation Inspection?</b> | <ul style="list-style-type: none"> <li>• Reinforced Concrete Roof Deck</li> <li>• Roof Covering (Non-FBC or FBC)</li> <li>• Roof Deck Attachment (Level A-6d-6”/12”, Level B-8d-6”/12”, Level C-8d-6”/6”, Reinforced Concrete Roof Deck)</li> <li>• Roof Wall Attachment Features (Toe Nails, Clips, Single Wraps, Double Wraps, Reinforced Concrete Roof Deck)</li> <li>• Secondary Water Resistance (SWR)</li> <li>• Opening Protection (Hurricane Impact, Basic Impact, None)</li> <li>• Roof Shape (Hip, Gable, Flat, Other)</li> </ul>  |
| <b>Wind Mitigation Inspection Documentation Requirements</b>         | <ul style="list-style-type: none"> <li>• The inspection must be no more than 5 years old.</li> <li>• The inspection must be in the primary insured's name only; an inspection in a previous owner's name does not qualify.</li> <li>• The inspection must be completed using the approved Uniform Mitigation Verification Inspection Form version 2012.</li> <li>• The inspection must include the colored photos taken by the inspector.</li> <li>• Document must be received within 30 days of the policy purchase date for New Business. <ul style="list-style-type: none"> <li>○ Policyholders who fail to provide a copy of the inspection within 30 days will have any additional discounts removed, and the policy will be rated with defaults based on YOC and roof age.</li> </ul> </li> <li>• Documents received mid-term resulting in a premium change will be applied no earlier than the effective date of the current term or the date of the inspection, whichever is later.</li> </ul> |
| <b>How Do I Add Discounts to an Active Policy?</b>                   | <ul style="list-style-type: none"> <li>• Request that the inspection be emailed to TRUE at <a href="mailto:memberservice@trueins.com">memberservice@trueins.com</a> (members) or <a href="mailto:agent-support@trueins.com">agent-support@trueins.com</a> (agents) and retrieve the document from Zendesk.</li> <li>• Use the <b>Wind Mitigation Inspection</b> below to apply the correct credits.</li> </ul>   |
| <b>How do I know what the default credits are?</b>                   | <ul style="list-style-type: none"> <li>• Use the <b>Wind Mitigation Default Credit Chart</b> below to determine the correct default credits.</li> </ul>  |

## Wind Mitigation Default Credit Chart

## Wind Mitigation Default Credit Chart

| YOC  | Roof Year | Roof Cover   | Roof Deck | Roof to Wall | OP         | SWR       |
|--|-----------|--------------|-----------|--------------|------------|-----------|
| Pre-2002   | Pre-2002  | Non-FBC      | A         | Toe Nail     | No         | No        |
| Pre-2002   | 2002+     | FBC          | C         | Toe Nail     | No         | No        |
| 2002+  | 2002+     | FBC          | C         | Clips        | No         | No        |
| The below credits are specific to counties below with a 2012+ YOC  |           |              |           |              |            |           |
| 2012+  | 2012+     | FBC          | C         | Clips        | Hurricane  | Yes       |
| Brevard  | Collier   | Glades       | Lee       | Miami-Dade   | Palm Beach | Sarasota  |
| Broward  | Desoto    | Hendry       | Manatee   | Monroe       | Pinellas   | St. Lucie |
| Charlotte  | Escambia  | Indian River | Martin    |              |            |           |
| Notes: All Reinforced Concrete Decks, Single Wraps, and Double Wraps require a Wind Mitigation Inspection be submitted |           |              |           |              |            |           |

## Wind Mitigation Inspection Example

### Uniform Mitigation Verification Inspection Form

Maintain a copy of this form and any documentation provided with the insurance policy

|  |                       |         |  |
|--|-----------------------|---------|--|
| Inspection Date: <b>The Inspection Date and all Owner Information is required.</b> |                       | RCR     |  |
| Owner Name: _____  |                       | Refer   |  |
| Address: <b>This Address must match property address on the policy</b>             | Contact Person: _____ | Level A |  |
| City: _____  | Home Phone: _____     | Level A |  |
| County: _____  | Work Phone: _____     |         |  |
| Insurance Company: _____   | Cell Phone: _____     |         |  |
| Year of Home: _____  | Policy #: _____       |         |  |
| # of Stories: _____  | Email: _____          |         |  |

NOTE: Any documentation used in validating the compliance or existence of each construction or mitigation attribute must accompany this form. At least one photograph must accompany this form to validate each attribute marked in questions 3 through 7. The insurer may ask additional questions regarding the mitigated feature(s) verified on this form.

- N/A** 1. **Building Code:** Was the structure built in compliance with the Florida Building Code (FBC 2001 or later) OR for homes located in the HVHZ (Miami-Dade or Broward counties), South Florida Building Code (SFBC-04)?
- ☐ A. Built in compliance with the FBC: Year Built \_\_\_\_\_. For homes built in 2002/2003 provide a permit application with a date after 3/1/2002: Building Permit Application Date 0000000000/\_\_\_\_/\_\_\_\_.
- ☐ B. For the HVHZ Only: Built in compliance with the SFBC-04: Year Built \_\_\_\_\_. For homes built in 1994, 1995, and 1996 provide a permit application with a date after 9/1/1994: Building Permit Application Date 0000000000/\_\_\_\_/\_\_\_\_.
- ☐ C. Unknown or does not meet the requirements of Answer "A" or "B"

- N/A** 2. **Roof Covering:** Select all roof covering types in use. Provide the permit application date OR FBC/MDC Product Approval number OR Year of Original Installation/Replacement OR indicate that no information was available to verify compliance for each roof covering identified.

| 2:1 Roof Covering Type:                                | Permit Application Date | FBC or MDC Product Approval # | Year of Original Installation or Replacement | No Information Provided for Compliance |
|--|-------------------------|-------------------------------|--|--|
| <input type="checkbox"/> 1. Asphalt/Flangeless Shingle | ____/____/____          | _____                         | _____  | <input type="checkbox"/>               |
| <input type="checkbox"/> 2. Concrete/Clay Tile         | ____/____/____          | _____                         | _____  | <input type="checkbox"/>               |
| <input type="checkbox"/> 3. Metal                      | ____/____/____          | _____                         | _____  | <input type="checkbox"/>               |
| <input type="checkbox"/> 4. Built Up                   | ____/____/____          | _____                         | _____  | <input type="checkbox"/>               |
| <input type="checkbox"/> 5. Membrane                   | ____/____/____          | _____                         | _____  | <input type="checkbox"/>               |
| <input type="checkbox"/> 6. Other _____                | ____/____/____          | _____                         | _____  | <input type="checkbox"/>               |

- FBC** ☐ A. All roof coverings listed above meet the FBC with a FBC or Miami-Dade Product Approval listing current at time of installation OR have a roofing permit application date on or after 3/1/02 OR the roof is original and built in 2004 or later.
- FBC** ☐ B. All roof coverings have a Miami-Dade Product Approval listing current at time of installation OR (for the HVHZ only) a roofing permit application after 9/1/1994 and before 3/1/2002 OR the roof is original and built in 1997 or later.
- Non-FBC** ☐ C. One or more roof coverings do not meet the requirements of Answer "A" or "B".
- Non-FBC** ☐ D. No roof coverings meet the requirements of Answer "A" or "B".

3. **Roof Deck Attachment:** What is the **weakest** form of roof deck attachment?
- Level A** ☐ A. Plywood/Oriented strand board (OSB) roof sheathing attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by staples or 6d nails spaced at 6" along the edge and 12" in the field. -OR- Batten decking supporting wood shakes or wood shingles. -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that has an equivalent mean uplift less than that required for Options B or C below.
- Level B** ☐ B. Plywood/OSB roof sheathing with a minimum thickness of 7/16" inch attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by 8d common nails spaced a maximum of 12" inches in the field. -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that is shown to have an equivalent or greater resistance 8d nails spaced a maximum of 12 inches in the field or has a mean uplift resistance of at least 103 psf.
- Level C** ☐ C. Plywood/OSB roof sheathing with a minimum thickness of 7/16" inch attached to the roof truss/rafter (spaced a maximum of 24" inches o.c.) by 8d common nails spaced a maximum of 6" inches in the field. -OR- Dimensional Lumber/Tongue & Groove decking with a minimum of 2 nails per board (or 1 nail per board if each board is equal to or less than 6 inches in width). -OR- Any system of screws, nails, adhesives, other deck fastening system or truss/rafter spacing that is shown to have an equivalent

Inspectors Initials \_\_\_\_\_ Property Address \_\_\_\_\_ Initials and Property Address are needed on each page

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure.  
OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155 Page 1 of 4

or greater resistance than 8d common nails spaced a maximum of 6 inches in the field or has a mean uplift resistance of at least 182 psf.

- ☐ D. Reinforced Concrete Roof Deck.
- ☐ E. Other: \_\_\_\_\_
- ☐ F. Unknown or unidentified.
- ☐ G. No attic access.

4. **Roof to Wall Attachment:** What is the **WEAKEST** roof to wall connection? (Do not include attachment of hip/valley jacks within 5 feet of the inside or outside corner of the roof in determination of WEAKEST type)

- Toe Nails** ☐ A. Toe Nails
- ☐ Truss/rafter anchored to top plate of wall using nails driven at an angle through the truss/rafter and attached to the top plate of the wall, or
- ☐ Metal connectors that do not meet the minimal conditions or requirements of B, C, or D

**Minimal conditions to qualify for categories B, C, or D. All visible metal connectors are:**

- ☐ Secured to truss/rafter with a minimum of three (3) nails, and
- ☐ Attached to the wall top plate of the wall framing, or embedded in the bond beam, with less than a 1/2" gap from the blocking or truss/rafter and blocked no more than 1.5" of the truss/rafter, and free of visible severe corrosion.

- Clips** ☐ B. Clips
- ☐ Metal connectors that do not wrap over the top of the truss/rafter, or
- ☐ Metal connectors with a minimum of 1 strap that wraps over the top of the truss/rafter and does not meet the nail position requirements of C or D, but is secured with a minimum of 3 nails.

- Single Wraps** ☐ C. Single Wraps
- Metal connectors consisting of a single strap that wraps over the top of the truss/rafter and is secured with a minimum of 2 nails on the front side and a minimum of 1 nail on the opposing side.

- Double Wraps** ☐ D. Double Wraps
- ☐ Metal Connectors consisting of 2 separate straps that are attached to the wall frame, or embedded in the bond beam, on either side of the truss/rafter where each strap wraps over the top of the truss/rafter and is secured with a minimum of 2 nails on the front side, and a minimum of 1 nail on the opposing side, or
- ☐ Metal connectors consisting of a single strap that wraps over the top of the truss/rafter, is secured to the wall on both sides, and is secured to the top plate with a minimum of three nails on each side.

- Refer** ☐ E. Structural Anchor bolts structurally connected or reinforced concrete roof.

- Refer** ☐ F. Other: \_\_\_\_\_

- Toe** ☐ G. Unknown or unidentified

- Nails** ☐ H. No attic access

5. **Roof Geometry:** What is the roof shape? (Do not consider roofs of porches or carports that are attached only to the fascia or wall of the host structure over unenclosed space in the determination of roof perimeter or roof area for roof geometry classification).

- Hip** ☐ A. Hip Roof Hip roof with no other roof shapes greater than 10% of the total roof system perimeter.  
Total length of non-hip features: \_\_\_\_\_ feet; Total roof system perimeter: \_\_\_\_\_ feet
- Flat** ☐ B. Flat Roof Roof on a building with 5 or more units where at least 90% of the main roof area has a roof slope of less than 2:12. Roof area with slope less than 2:12 \_\_\_\_\_ sq ft; Total roof area \_\_\_\_\_ sq ft
- Gable** ☐ C. Other Roof Any roof that does not qualify as either (A) or (B) above. **Leave as agent quoted if Gable or Other**

6. **Secondary Water Resistance (SWR):** (standard underlayments or ho-napped felts do not qualify as an SWR)

- SWR - Yes** ☐ A. SWR (also called Sealed Roof Deck) Self-adhering polymer modified-bitumen roofing underlayment applied directly to the sheathing or foam adhesive SWR barrier (not foamed-on insulation) applied as a supplemental means to protect the dwelling from water intrusion in the event of roof covering loss.

- SWR - No** ☐ B. No SWR.

- SWR - No** ☐ C. Unknown or undetermined.

Inspectors Initials \_\_\_\_\_ Property Address \_\_\_\_\_ Initials and Property Address are needed on each page

\*This verification form is valid for up to five (5) years provided no material changes have been made to the structure or inaccuracies found on the form.  
OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155 Page 2 of 4

7. **Opening Protection:** What is the **weakest** form of wind borne debris protection installed on the structure? **First**, use the table to determine the weakest form of protection for each category of opening. **Second**, (a) check one answer below (A, B, C, N, or X) based upon the lowest protection level for ALL Glazed openings and (b) check the protection level for all Non-Glazed openings (.1, .2, or .3) as applicable.

## Opening Protection Level Chart

Place an "X" in each row to identify all forms of protection in use for each opening type. Check only one answer below (A thru X), based on the weakest form of protection (lowest row) for any of the Glazed openings and indicate the weakest form of protection (lowest row) for Non-Glazed openings.

|     |   | Glazed Openings        |              |           | Non-Glazed Openings |              |
|-----|---|------------------------|--------------|-----------|---------------------|--------------|
|     |   | Windows or Entry Doors | Garage Doors | Skylights | Entry Doors         | Garage Doors |
| N/A | Not Applicable- there are no openings of this type on the structure   |                        |              |           |                     |              |
| A   | Verified cyclic pressure & large missile (9-lb for windows doors/6.5 lb for skylights)  |                        |              |           |                     |              |
| B   | Verified cyclic pressure & large missile (4-8 lb for windows doors/2 lb for skylights)  |                        |              |           |                     |              |
| C   | Verified plywood/OSB meeting Table 1609.1.2 of the FBC 2007   |                        |              |           |                     |              |
| D   | Verified Non-Glazed Entry or Garage doors indicating compliance with ASTM E 330, ANSI/DASMA 108, or PA/TAS 202 for wind pressure resistance |                        |              |           |                     |              |
| N   | Opening Protection products that appear to be A or B but are not verified   |                        |              |           |                     |              |
|     | Other protective coverings that cannot be identified as A, B, or C  |                        |              |           |                     |              |
| X   | No Windborne Debris Protection  |                        |              |           |                     |              |

**A. Exterior Openings Cyclic Pressure and 9-lb Large Missile (4.5 lb for skylights only)** All Glazed openings are protected at a minimum, with impact resistant coverings or products listed as wind borne debris protection devices in the product approval system of the State of Florida or Miami-Dade County and meet the requirements of one of the following for "Cyclic Pressure and Large Missile Impact" (Level A in the table above).

- Miami-Dade County PA 201, 202, and 203
- Florida Building Code Testing Application Standard (TAS) 201, 202, and 203
- American Society for Testing and Materials (ASTM) E 1886 and ASTM E 1996
- Southern Standards Technical Document (SSTD) 12
- For Skylights Only: ASTM E 1886 and ASTM E 1996
- For Garage Doors Only: ANSI/DASMA 115

**Hurricane** ☐ A.1 All Non-Glazed openings classified as A in the table above, or no Non-Glazed openings exist

**Hurricane** ☐ A.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level B, C, N, or X in the table above

**Hurricane** ☐ A.3 One or More Non-Glazed Openings is classified as Level B, C, N, or X in the table above

**B. Exterior Opening Protection- Cyclic Pressure and 4 to 8-lb Large Missile (2-4.5 lb for skylights only)** All Glazed openings are protected, at a minimum, with impact resistant coverings or products listed as windborne debris protection devices in the product approval system of the State of Florida or Miami-Dade County and meet the requirements of one of the following for "Cyclic Pressure and Large Missile Impact" (Level B in the table above):

- ASTM E 1886 and ASTM E 1996 (Large Missile - 4.5 lb.)
- SSTD 12 (Large Missile - 4 lb. to 8 lb.)
- For Skylights Only: ASTM E 1886 and ASTM E 1996 (Large Missile - 2 to 4.5 lb.)

**Basic** ☐ B.1 All Non-Glazed openings classified as A or B in the table above, or no Non-Glazed openings exist

**Basic** ☐ B.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level C, N, or X in the table above

**Basic** ☐ B.3 One or More Non-Glazed openings is classified as Level C, N, or X in the table above

**C. Exterior Opening Protection- Wood Structural Panels meeting FBC 2007** All Glazed openings are covered with plywood/OSB meeting the requirements of Table 1609.1.2 of the FBC 2007 (Level C in the table above).

**None** ☐ C.1 All Non-Glazed openings classified as A, B, or C in the table above, or no Non-Glazed openings exist

**None** ☐ C.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level N or X in the table above

**None** ☐ C.3 One or More Non-Glazed openings is classified as Level N or X in the table above

Inspectors Initials \_\_\_\_\_ Property Address \_\_\_\_\_ **Initials and Property Address are needed on each page**

"This verification form is valid for up to five (5) years provided no material changes have been made to the structure or inaccuracies found on the form.

OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

Page 3 of 4

☐ **N. Exterior Opening Protection (unverified shutter systems with no documentation)** All Glazed openings are protected with protective coverings not meeting the requirements of Answer "A", "B", or "C" or systems that appear to meet Answer "A" or "B" with no documentation of compliance (Level N in the table above).

☐ N.1 All Non-Glazed openings classified as Level A, B, C, or N in the table above, or no Non-Glazed openings exist

☐ N.2 One or More Non-Glazed openings classified as Level D in the table above, and no Non-Glazed openings classified as Level X in the table above

☐ N.3 One or More Non-Glazed openings is classified as Level X in the table above

☐ **X. None or Some Glazed Openings** One or more Glazed openings classified and Level X in the table above.

**This section must be completed in full**

**MITIGATION INSPECTIONS MUST BE CERTIFIED BY A QUALIFIED INSPECTOR.**  
**Section 627.711(2), Florida Statutes, provides a listing of individuals who may sign this form.**

|                                 |                     |                                 |
|---------------------------------|---------------------|---------------------------------|
| Qualified Inspector Name: _____ | License Type: _____ | License or Certificate #: _____ |
| Inspection Company: _____       |                     | Phone: _____                    |

**Qualified Inspector - I hold an active license as a: (check one)**

- ☐ Home inspector licensed under Section 468.8314, Florida Statutes who has completed the statutory number of hours of hurricane mitigation training approved by the Construction Industry Licensing Board and completion of a proficiency exam.
- ☐ Building code inspector certified under Section 468.607, Florida Statutes.
- ☐ General, building or residential contractor licensed under Section 489.111, Florida Statutes.
- ☐ Professional engineer licensed under Section 471.015, Florida Statutes.
- ☐ Professional architect licensed under Section 481.213, Florida Statutes.
- ☐ Any other individual or entity recognized by the insurer as possessing the necessary qualifications to properly complete a uniform mitigation verification form pursuant to Section 627.711(2), Florida Statutes.

**One box from this section must be checked**

**Individuals other than licensed contractors licensed under Section 489.111, Florida Statutes, or professional engineer licensed under Section 471.015, Florida Statutes, must inspect the structures personally and not through employees or other persons. Licensees under s.471.015 or s.489.111 may authorize a direct employee who possesses the requisite skill, knowledge, and experience to conduct a mitigation verification inspection.**

I, \_\_\_\_\_ am a qualified inspector and I personally performed the inspection or (licensed (print name)

contractors and professional engineers only) I had my employee (\_\_\_\_\_ ) perform the inspection (print name of inspector)

and I agree to be responsible for his/her work. **Inspector name/employee, signature, date is required**

Qualified Inspector Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**An individual or entity who knowingly or through gross negligence provides a false or fraudulent mitigation verification form is subject to investigation by the Florida Division of Insurance Fraud and may be subject to administrative action by the appropriate licensing agency or to criminal prosecution. (Section 627.711(4)-7), Florida Statutes) The Qualified Inspector who certifies this form shall be directly liable for the misconduct of employees as if the authorized mitigation inspector personally performed the inspection.**

**Homeowner to complete:** I certify that the named Qualified Inspector or his or her employee did perform an inspection of the residence identified on this form and that proof of identification was provided to me or my Authorized Representative.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_  
**Homeowner signature and date is preferred**

**An individual or entity who knowingly provides or utters a false or fraudulent mitigation verification form with the intent to obtain or receive a discount on an insurance premium to which the individual or entity is not entitled commits a misdemeanor of the first degree. (Section 627.711(7), Florida Statutes)**

The definitions on this form are for inspection purposes only and cannot be used to certify any product or construction feature as offering protection from hurricanes.

Inspectors Initials \_\_\_\_\_ Property Address \_\_\_\_\_ **Initials and Property Address are needed on each page**

"This verification form is valid for up to five (5) years provided no material changes have been made to the structure or inaccuracies found on the form.

OIR-B1-1802 (Rev. 01/12) Adopted by Rule 690-170.0155

Page 4 of 4